

# JOHN GILBERT WATER TREATMENT PLANT POINT 1

## 2022/2023

Licensee: Dubbo Regional Council

EPL No: 11694

Date Sample Taken: 14/06/2023	Date Obtained: 26/06/2023	Date Published 21/08/2023	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	4
1		pH	6.5-8.5	mg/L	8.1

Date Sample Taken: 22/05/2023	Date Obtained: 31/05/2023	Date Published 26/06/2023	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	4
1		pH	6.5-8.5	mg/L	8.1

Date Sample Taken: 25/04/2023	Date Obtained: 08/05/2023	Date Published 19/05/2023	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	3
1		pH	6.5-8.5	mg/L	8

Date Sample Taken: 15/03/2023	Date Obtained: 30/03/2023	Date Published 19/05/2023	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	4
1		pH	6.5-8.5	mg/L	7.8

Date Sample Taken: 01/02/2023	Date Obtained: 15/02/2023	Date Published 29/03/2023	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	5
1		pH	6.5-8.5	mg/L	7.9

Date Sample Taken:	Date Obtained:	Date Published 28/02/2023	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	N/A
1		Oil and Grease	0-2	mg/L	N/A
1		Total Suspended Solids	0-15	mg/L	N/A
1		pH	6.5-8.5	mg/L	N/A

Date Sample Taken: 13/12/2022	Date Obtained: 23/12/2022	Date Published 30/01/2023	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	9
1		pH	6.5-8.5	mg/L	7.9

Date Sample Taken: 23/11/2022	Date Obtained: 24/11/2022	Date Published 13/12/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	8
1		pH	6.5-8.5	mg/L	8

Date Sample Taken: October 2022	Date Obtained: October 2022	Date Published 18/11/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	N/A
1		Oil and Grease	0-2	mg/L	N/A
1		Total Suspended Solids	0-15	mg/L	N/A
1		pH	6.5-8.5	mg/L	N/A

Date Sample Taken: 25/09/2022	Date Obtained: 26/09/2022	Date Published 18/11/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	
1		pH	6.5-8.5	mg/L	7.8

Date Sample Taken: 29/08/2022	Date Obtained: 30/08/2022	Date Published 18/11/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	
1		pH	6.5-8.5	mg/L	8

Date Sample Taken: 07/07/2022	Date Obtained: 08/07/2022	Date Published 05/08/2022	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<5
1		Total Suspended Solids	0-15	mg/L	3
1		pH	6.5-8.5	mg/L	7.9