

DUBBO SEWAGE TREATMENT PLANT POINT 2

2024/2025

Licensee: Dubbo Regional Council

EPL No: 3850

Date Sample Taken: 1/10/2024	Date Sample Result Obtained: 10/10/2024			Date Published: 11/11/2024
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	4
	Nitrogen (total)	0 - 15	mg/L	2.5
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.22
	Total Suspended Solids	0 - 30	mg/L	11

Date Sample Taken: 4/9/2024	Date Sample Result Obtained: 13/9/2024			Date Published: 21/10/2024
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	6
	Nitrogen (total)	0 - 15	mg/L	3.3
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.2
	Total Suspended Solids	0 - 30	mg/L	26

Date Sample Taken: 7/8/2024	Date Sample Result Obtained: 15/8/2024			Date Published: 16/9/2024
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	2
	Nitrogen (total)	0 - 15	mg/L	3.5
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.04
	Total Suspended Solids	0 - 30	mg/L	4

Date Sample Taken: 3/7/2024	Date Sample Result Obtained: 15/7/2024			Date Published: 12/8/2024
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	4
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.04
	Total Suspended Solids	0 - 30	mg/L	<2