

JOHN GILBERT WATER TREATMENT PLANT POINT 1

2024/2025

Licensee: Dubbo Regional Council

EPL No: 11694

Date Sample Taken: 29/10/2024	Date Obtained: 8/11/2024	Date Published: 11/11/2024	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	9
1		pH	6.5-8.5	mg/L	8

Date Sample Taken: 24/9/2024	Date Obtained: 10/10/2024	Date Published: 21/10/2024	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	5
1		pH	6.5-8.5	mg/L	7.9

Date Sample Taken: 28/8/2024	Date Obtained: 7/9/2024	Date Published: 16/9/2024	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	5
1		pH	6.5-8.5	mg/L	8.3

Date Sample Taken: 23/7/2024	Date Obtained: 2/8/2024	Date Published: 12/8/2024	Licence Number: 11694		
Sampling Point	Monitoring frequency required by licence	Pollutant	Acceptable Range	Unit	Result
1	Monthly during discharge	Biochemical Oxygen Demand	0-10	mg/L	<2
1		Oil and Grease	0-2	mg/L	<1
1		Total Suspended Solids	0-15	mg/L	2
1		pH	6.5-8.5	mg/L	7.9