

# DUBBO SEWAGE TREATMENT PLANT POINT 2

## 2022/2023

Licensee: Dubbo Regional Council

EPL No: 3850

Date Sample Taken: 06/06/2023	Date Sample Result Obtained: 16/06/2023			Date Published: 21/08/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	2
	Nitrogen (total)	0 - 15	mg/L	6.58
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	5.06
	Total Suspended Solids	0 - 30	mg/L	4

Date Sample Taken: 02/05/2023	Date Sample Result Obtained: 12/05/2023			Date Published: 26/06/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	4.93
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	5.22
	Total Suspended Solids	0 - 30	mg/L	2

Date Sample Taken: 5/04/2023	Date Sample Result Obtained: 17/04/2023			Date Published: 19/05/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	3
	Nitrogen (total)	0 - 15	mg/L	3.78
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	4.46
	Total Suspended Solids	0 - 30	mg/L	7

Date Sample Taken: 7/03/2023	Date Sample Result Obtained: 17/03/2023			Date Published: 19/05/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	2
	Nitrogen (total)	0 - 15	mg/L	3.55
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	5.14
	Total Suspended Solids	0 - 30	mg/L	12

Date Sample Taken: 07/02/2023	Date Sample Result Obtained: 17/02/2023			Date Published: 29/03/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	3.34
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	4.8
	Total Suspended Solids	0 - 30	mg/L	3

Date Sample Taken: 04/01/2023	Date Sample Result Obtained: 16/01/2023			Date Published: 21/02/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	3
	Nitrogen (total)	0 - 15	mg/L	1.5
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.18
	Total Suspended Solids	0 - 30	mg/L	<2

Date Sample Taken: 06/12/2022	Date Sample Result Obtained: 15/12/2022			Date Published: 30/01/2023
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	2.7
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.38
	Total Suspended Solids	0 - 30	mg/L	<2

Date Sample Taken: 08/11/2022	Date Sample Result Obtained: 17/11/2022			Date Published: 13/12/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	3.64
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	2.78
	Total Suspended Solids	0 - 30	mg/L	4

Date Sample Taken: 04/10/2022	Date Sample Result Obtained: 05/10/2022			Date Published: 18/11/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	2.33
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.16
	Total Suspended Solids	0 - 30	mg/L	<2

Date Sample Taken: 05/09/2022	Date Sample Result Obtained: 06/09/2022			Date Published: 18/11/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	2.66
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	2.94
	Total Suspended Solids	0 - 30	mg/L	<2

Date Sample Taken: 01/08/2022	Date Sample Result Obtained: 02/08/2022			Date Published: 18/11/2022
Sampling Point	Pollutant	Acceptable Range	Unit	Result
2	Biochemical Oxygen Demand	0 - 30	mg/L	2
	Nitrogen (total)	0 - 15	mg/L	3.43
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.52
	Total Suspended Solids	0 - 30	mg/L	<2

Date Sample Taken: 07/07/2022	Date Sample Result Obtained: 08/07/2022			Date Published: 05/08/2022
<b>Sampling Point</b>	<b>Pollutant</b>	<b>Acceptable Range</b>	<b>Unit</b>	<b>Result</b>
2	Biochemical Oxygen Demand	0 - 30	mg/L	<2
	Nitrogen (total)	0 - 15	mg/L	3.08
	Oil and Grease	0 - 10	mg/L	<5
	Phosphorus	0 - 10	mg/L	3.67
	Total Suspended Solids	0 - 30	mg/L	3